



Intertek

ETL Verified Certificate of Conformance Number: 100589213CRT-001f


On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Rendered to:

Belden Wire & Cable B.V.
 Edisonstraat 9
 5928 PG Venlo, Netherlands
 Contact: Mr. Rob van Neerven

Product Tested:

4-Connector Channel



<u>Component ID</u>	<u>Manufacturer</u>	<u>Part Number</u>	<u>Description</u>
1	Belden	NXPC-D2RS8G-R7AT-R7AT-10.0	Modular Cord 10 ft
2	Belden	AX103116 / AX102283	Patch Panel / Keystone Jack
3	Belden	NXPC-D2RS8G-R7AT-R7AT-07.0	Modular Cord 7 ft
4	Belden	10GX24 LSOH	Horizontal Cable
5	Belden	NXPC-D2RS8G-R7BT-ZZZZ-15.0	Modular Cord 15 ft

Standard(s)/Specification: ANSI/TIA-568.2-D Category 6A and ISO/IEC 11801-1 Class E_A with the applicable electrical transmission characteristics

Product(s) Literature May Include: ETL Verified 4-Connector Channel to ANSI/TIA-568.2-D Category 6A and ISO/IEC 11801-1 Class E_A, along with channel illustration, and parts numbers.

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: June 14, 2012

Date Revised: June 08, 2023

Approved By: *Antoine Pelletier*
 Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.