

STANDARD INFORMATION

Standard: UL Subject 111

Standard ID: Outline of Investigation for Multioutlet Assemblies [UL SUBJECT 111:2023 Ed.8]

Previous Standard ID: Outline of Investigation for Multioutlet Assemblies [UL SUBJECT 111:2021 Ed.7]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **March 9, 2025**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Additional requirements for multioutlet assembly provided with hospital grade receptacles. Specific details of new/ revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
8	Info	Electrical Construction
8.5	Info	Wiring devices
8.5.6	Info	Hospital grade receptacle outlets shall comply with the requirements for Hospital Grade Receptacles in the Standard for Attachment Plugs and Receptacles, UL 498.
	Info	MARKINGS
36	Info	Markings
36.2	Info	General
		<i>New clause added;</i>
36.2.20		In accordance with 8.5.6, a multioutlet assembly provided with hospital grade receptacles shall be marked where visible during installation with the word "WARNING" and the following or the equivalent: "Do Not Use this Multioutlet Assembly in General Patient Care Areas or Critical Patient Care Areas. It has not been evaluated for installation in accordance with the requirements of Article 517 of the National Electrical Code, ANSI/NFPA 70." The marking shall be a tear-resistant flag label permanently affixed to the assembly. The background shall be Safety Orange and the verbiage shall be in Black in accordance with ANSI Safety Color Code Z535.1 and Product Safety Signs and Labels Z535.4.